



A P P R O V A L S ®

Certificate of Suitability

Certificate No.: SAA161181

Certificate Holder: Caledonian Cables Limited
1/F CMA Building,
64-66 Connaught Road,
Central
Hong Kong

Class Description: Non-Declared
Product Description: Cable (Single core, sheathed and circular)
Brand Name: CALEDONIAN
Model No.: CU/XLPE X-90/PVC 5V-90 1C* Series
Markings: 0.6/1kV
Standard: AS/NZS 5000.1:2005 Inc A1
Conditions: Nil

Certification Mark: SAA161181 or RCM

Date First Registered: 14 June 2016
Date of Expiry: 14 June 2021


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 14-06-16 161181/1



A P P R O V A L S ®

Certificate of Suitability

Addendum

Certificate No.: SAA161181

Date of Issue: 14 June 2016

Class Description: Non-Declared

Product Description: Cable (Single core, sheathed and circular)

General Modification:

For CU/XLPE X-90/PVC 5V-90 1C* Series:

'*' denotes core cross-sectional area in mm² and can be 1.5-630mm².

Additional Models

Description

CU/XLPE X-90/PVC 5V-90 2C* Series

Similar to CU/XLPE X-90/PVC 5V-90 1C* Series except for 2 core.

CU/XLPE X-90/PVC 5V-90 3C(2C+E)* Series

Similar to CU/XLPE X-90/PVC 5V-90 1C* Series except for 2 core + Earth.

CU/XLPE X-90/PVC 5V-90 4C(3C+E)* Series

Similar to CU/XLPE X-90/PVC 5V-90 1C* Series except for 3 core + Earth.

CU/XLPE X-90/PVC 5V-90 5C(4C+E)* Series

Similar to CU/XLPE X-90/PVC 5V-90 1C* Series except for 4 core + Earth.


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 14-06-16 161181/2